# **Compact Photoelectric Sensor with Built-in Amplifier**

# E3Z-LS

CSM\_E3Z-LS\_DS\_E\_9\_1

# Distance-settable Sensor Unaffected by Workpiece Color and Background

- Distance-settable triangulation model unaffected by color.
- Simple positioning settings using a clear LED spot. (E3Z-LS\(\sigma\)3/LS\(\sigma\)8)
- Detect minute steps.





Be sure to read *Safety Precautions* on page 8.

For the most recent information on models that have been certified for safety standards, refer to your OMRON website.

# **Ordering Information**

### Sensors (Refer to Dimensions on page 10.)

Red light

Sensing	Appearance	Connection method	Sensing distance (white paper)	Model		
method	method Appearance Connection method Sensing distance (write paper)			NPN output	PNP output	
Distance- settable	<b>.</b>	Pre-wired (2 m)	20 mm 40 mm 200 mm  BGS (at min. setting) Incident light level threshold (fixed)	E3Z-LS61 2M *1	E3Z-LS81 2M *1	
		Connector (M8, 4 pins)	FGS (at min. setting) FGS (at max. setting)	E3Z-LS66	E3Z-LS86	
	<b>←</b>	Pre-wired (2 m)	2 mm 20 mm 80 mm BGS (at min. setting)	E3Z-LS63 2M	E3Z-LS83 2M *2	
		Connector (M8, 4 pins)	BGS (at max. setting)	E3Z-LS68	E3Z-LS88	

<sup>\*1.</sup> M12 Standard Pre-wired Connector Models are also available. When ordering, add "-M1J 0.3M" to the end of the model number (e.g., E3Z-LS61-M1J 0.3M). The cable is 0.3 m long.

### **Accessories (Order Separately)**

**Mounting Brackets** 

### Sensor I/O Connectors (Sockets on One Cable End)

(Models for Connectors: A Connector is not provided with the Sensor. Be sure to order a Connector separately.) (Refer to Dimensions on XS3)

Cable specification	Appearance		Type of cable		Model
	Straight *1		2 m	- 4-wire	XS3F-M421-402-A
Standard M8 cable			5 m		XS3F-M421-405-A
Staridard ivio Cable	L-shaped *1 *2		2 m		XS3F-M422-402-A
			5 m		XS3F-M422-405-A

<sup>\*1.</sup> The connector will not rotate after connecting.

OMRON 1

<sup>\*2.</sup> M12 Pre-wired Smartclick Connector Models are also available.
When ordering, add "-M1TJ 0.3M" to the end of the model number (e.g., E3Z-LS83-M1TJ 0.3M).
The cable is 0.3 m long.

<sup>\*2.</sup> The cable is fixed at an angle of 180° from the sensor emitter/receiver surface.


# **Ratings and Specifications**

Sensing method		Distance-settable Distance-settable						
Model NPN output		E3Z-LS61	E3Z-LS66	E3Z-LS63 E3Z-LS68				
Item	PNP output	E3Z-LS81	E3Z-LS86	E3Z-LS83	E3Z-LS88			
	BGS	White or black paper (100 > tance	(100 mm): 20 mm to set dis-	2 mm to set distance (80 r	2 mm to set distance (80 mm max.)			
Sensing distance	FGS	min.	n): Set distance to 200 mm n): Set distance to 160 mm					
Setting range	е	White paper (100 $\times$ 100 mi Black paper (100 $\times$ 100 mr		White paper (100 × 100 mm): 20 to 80 mm				
Differential to	ravel	10% of set distance max. (vs. Sensing Distance on page 2)		2% of set distance max.				
Reflectivity of (black/white	characteristic error)	10% of set distance max.		5% of set distance max.				
Light source	(wavelength)	Red LED (680 nm)		Red LED (650 nm)				
Power suppl	y voltage	12 to 24 VDC ±10%, ripple	(p-p): 10% max.					
Current cons	sumption	30 mA max.						
Control output		Load power supply voltage: 26.4 VDC max., Load current: 100 mA max. (residual voltage 1 V max.), Open collector output (NPN or PNP depending on model) Light-ON/Dark-ON switch selectable						
BGS/FGS se	lection	BGS: Open or connected t FGS: Connected to Vcc	o GND	BGS: Open or connected to GND				
Protection ci	ircuits	Reversed power supply polarity protection, Output short-circuit protection, Mutual interference prevention						
Response tir	ne	Operate or reset: 1 ms max.						
Distance set	ting	5-turn endless adjuster						
Ambient illur (Receiver sic		Incandescent lamp: 3,000 lx max.; Sunlight: 10,000 lx max.						
Ambient tem	perature range	Operating: -25 to 55°C, Storage: -40 to 70°C (with no icing or condensation)						
Ambient hun	nidity range	Operating: 35% to 85%, Storage: 35% to 95% (with no condensation)						
Insulation re	sistance	20 MΩ min. at 500 VDC						
Dielectric str	ength	1,000 VAC at 50/60 Hz for 1 minute						
Vibration res	sistance	Destruction: 10 to 55 Hz, 1.5-mm double amplitude for 2 hours each in X, Y, and Z directions						
Shock resist	ance	Destruction: 500 m/s² for 3 times each in X, Y, and Z directions						
Degree of protection		IP67 (IEC 60529)						
Connection method		Pre-wired (standard lengths: 2 m and 0.5 m)	Connector (M8, 4 pins)	Pre-wired (standard lengths: 2 m and 0.5 m)	Connector (M8, 4 pins)			
Indicators		Operation indicator (orange), Stability indicator (green)						
Weight (packed state)		Pre-wired Sensors, 2 m: Approx. 65 g	Approx. 20 g	Pre-wired Sensors, 2 m: Approx. 65 g	Approx. 20 g			
Material	Case	PBT (polybutylene terephthalate)						
ivialei iai	Lens	Modified polyarylate resin						
Accessories		Instruction manual (Mounting Brackets must be ordered separately.)						


# **Engineering Data (Reference Value)**

### **Operating Range**


### E3Z-LS□1/LS□6 BGS



### **FGS**




### E3Z-LS 3/LS 8




### **Spot Diameter vs. Sensing Distance**

### E3Z-LS 1/LS 6




E3Z-LS 3/LS 8




## **Close-range Characteristics**

## E3Z-LS 1/LS 6




## E3Z-LS 3/LS 8




## **Differential Travel vs. Sensing Distance**

### E3Z-LS 1/LS 6




### E3Z-LS 3/LS 8




### **Sensing Object Angle Characteristics**

### E3Z-LS 1/LS 6

### Vertical




### Horizontal




### E3Z-LS 3/LS 8

### Vertical




### Horizontal




### **FGS Mode Set Distance**

### E3Z-LS□1/LS□6 White Paper




### **Black Paper**




## Sensing Distance vs. Sensing Object Material

### E3Z-LS 1/LS 6


### Set Distance of 40 mm using White Paper




Set Distance of 200 mm using White Paper



E3Z-LS□3/LS□8
Set Distance of 20 mm using White Paper



Set Distance of 80 mm using White Paper



# I/O Circuit Diagrams



Note: The VERY FAR region is supported only for FGS.
The incident light level threshold is fixed and cannot be set.

## **NPN Output**


Model	Operation mode	Timing charts	Operation selector	BGS/FGS selection method	Output circuit
E3Z-LS61 E3Z-LS66 E3Z-LS63 E3Z-LS68	Light-ON	Operation indicator (orange) OFF Output ON transistor OFF Load ON (e.g., relay) OFF (Between brown (1) and black (4) leads)	L side (LIGHT ON)	BGS: Either leave the pink wire (2) open or connect it to the blue wire (3).	Operation indicator (orange)  Stability   Brown   12 to 24 VDC
	Dark-ON	Operation indicator (orange) OFF Output ON transistor OFF Load ON (e.g., relay) OFF (Between brown (1) and black (4) leads)	D side (DARK ON)		
E3Z-LS61	Light-ON	Operation indicator (orange) OFF ON transistor OFF ON (e.g., relay) OFF (Between brown (1) and black (4) leads)	L side (LIGHT ON)	FGS: Connect the pink	Connector Pin Arrangement  (20) (3) (3)
E3Z-LS66	Dark-ON	Operation indicator (orange) OFF Output ON transistor OFF Load ON (e.g., relay) OFF (Between brown (1) and black (4) leads)	D side (DARK ON)	wire (2) to the brown wire (1).	

# **PNP Output**

Model	Operation mode	Timing charts	Operation selector	BGS/FGS selection method	Output circuit	
E3Z-LS81 E3Z-LS86 E3Z-LS83 E3Z-LS88	Light-ON	Operation indicator (orange) OFF Output transistor OFF Load ON (e.g., relay) OFF (Between blue (3) and black (4) leads)	L side (LIGHT ON)	BGS: Either leave the pink wire (2) open or connect it to the blue wire (3).		
	Dark-ON	Operation ON Indicator OFF Output ON transistor OFF OLoad ON (e.g., relay) OFF (Between blue (3) and black (4) leads)	D side (DARK ON)		Operation indicator (orange) Stability indicator (orange) Z <sub>D</sub> Black FGS  Photo-electric Sensor (Control output) 100 mA max.  Pink Load (relay)	
E3Z-LS81	Light-ON	Operation indicator (orange) OFF OFF OFF (Between blue (3) and black (4) leads)	L side (LIGHT ON)	FGS: Connect the pink	Connector Pin Arrangement  (2) (3) (1) (3)	
E3Z-LS86	Dark-ON	Operation indicator (orange) Output transistor OFF Load ON (e.g., relay) OFF (Between blue (3) and black (4) leads)	D side (DARK ON)			

# Plugs (Sensor I/O Connectors)

# M8 connector



# Pin arrangement

Classifi- cation	Wire color	Connector pin No.	Application
	Brown	1	Power supply (+V)
DC	White	2	BGS/FGS selection
	Blue	3	Power supply (0 V)
	Black	4	Output

# Nomenclature



# **Safety Precautions**

# Refer to Safety Precautions of the E3Z and Warranty and Limitations of Liability.

# **⚠** WARNING

This product is not designed or rated for ensuring safety of persons either directly or indirectly. Do not use it for such purposes.



# <u> (</u> Caution

Do not connect an AC power supply to the Sensor. If AC power (100 VAC or more) is supplied to the Sensor, it may explode or burn.



### **Precautions for Safe Use**

Be sure to abide by the following precautions for the safe operation of the Sensor.

### Wiring

# Power Supply Voltage and Output Load Power Supply Voltage

Make sure that the power supply to the Sensor is within the rated voltage range. If a voltage exceeding the rated voltage range is supplied to the Sensor, it may explode or burn.

### **Load Short-circuiting**

Do not short-circuit the load, otherwise the Sensor may be damaged.

### **Connection without Load**

Do not connect the power supply to the Sensor with no load connected, otherwise the internal elements may explode or burn.

### Operating Environment

Do not use the Sensor in locations with explosive or flammable gas.

### **Precautions for Correct Use**

Do not use the product in atmospheres or environments that exceed product ratings.

# Designing

### **Power Reset Time**

The Sensor is ready to operate 100 ms after the Sensor is turned ON. If the load and Sensor are connected to independent power supplies respectively, be sure to turn ON the Sensor before supplying power to the load.

### Wiring

### **Avoiding Malfunctions**

If using the Sensor with an inverter or servomotor, always ground the FG (frame ground) and G (ground) terminals, otherwise the Sensor may malfunction.

### Mounting

### **Mounting the Sensor**

- If Sensors are mounted face-to-face, make sure that the optical axes are not in opposition to each other. Otherwise, mutual interference may result.
- Always install the Sensor carefully so that the aperture angle range
  of the Sensor will not cause it to be directly exposed to intensive
  light, such as sunlight, fluorescent light, or incandescent light.
- Do not strike the Photoelectric Sensor with a hammer or any other tool during the installation of the Sensor, or the Sensor will lose its water-resistive properties.
- Use M3 screws to mount the Sensor.
- When mounting the case, make sure that the tightening torque applied to each screw does not exceed 0.54 N-m.

#### **M8 Connector**


- Always turn OFF the power supply to the Sensor before connecting or disconnecting the metal connector.
- Hold the connector cover to connect or disconnect it.
   If the XS3F is used, always tighten the connector cover by hand. Do not use pliers.

If the connector is not connected securely, it may be disconnected by vibration or the proper degree of protection of the Sensor may not be maintained. The appropriate tightening torque is 0.3 to 0.4 N.m

If other commercially available connectors are used, follow the recommended connector application conditions and recommended tightening torque specifications.

### **Mounting Directions**

 Make sure that the sensing side of the Sensor is parallel with the surface of the sensing objects.
 Normally, do not incline the Sensor towards the sensing object.




Glossy object

If the sensing object has a glossy surface, however, incline the Sensor by 5° to 10° as shown in the illustration, provided that the Sensor is not influenced by background objects.


 If there is a mirror-like object below the Sensor, the Sensor may not operate stably. Therefore, incline the Sensor or separate the Sensor

the Sensor or separate the Sensor from the mirror-like object as shown below.






• Do not install the Sensor in the wrong direction. Refer to the following illustration.




Install the Sensor as shown in the following illustration if each sensing object greatly differs in color or material.



### Adjusting

### **Indicator Operation**




Note: 1. If the stability indicator is lit, the detection/no detection status is stable within the rated ambient operating temperature (–25 to 55°C).


The VERY FAR region is supported only for FGS. The incident light threshold is fixed and cannot be set. The distance to the incident light threshold depends on the color and gloss of the sensing object's surface.

### • Inspection and Maintenance

### **Cleaning**

Never use paint thinners or other organic solvents to clean the surface of the product.





Terminal No.	Specifications		
1	+V		
2	BGS/FGS switchable		
3	0 V		
4	Output		

### Read and Understand This Catalog

Please read and understand this catalog before purchasing the products. Please consult your OMRON representative if you have any questions or comments

### Warranty and Limitations of Liability

### WARRANTY

OMRON's exclusive warranty is that the products are free from defects in materials and workmanship for a period of one year (or other period if specified) from date of sale by OMRON.

OMRON MAKES NO WARRANTY OR REPRESENTATION, EXPRESS OR IMPLIED, REGARDING NON-INFRINGEMENT, MERCHANTABILITY, OR FITNESS FOR PARTICULAR PURPOSE OF THE PRODUCTS. ANY BUYER OR USER ACKNOWLEDGES THAT THE BUYER OR USER ALONE HAS DETERMINED THAT THE PRODUCTS WILL SUITABLY MEET THE REQUIREMENTS OF THEIR INTENDED USE. OMRON DISCLAIMS ALL OTHER WARRANTIES, EXPRESS OR IMPLIED.

#### LIMITATIONS OF LIABILITY

OMRON SHALL NOT BE RESPONSIBLE FOR SPECIAL, INDIRECT, OR CONSEQUENTIAL DAMAGES, LOSS OF PROFITS OR COMMERCIAL LOSS IN ANY WAY CONNECTED WITH THE PRODUCTS, WHETHER SUCH CLAIM IS BASED ON CONTRACT, WARRANTY, NEGLIGENCE, OR STRICT LIABILITY.

In no event shall the responsibility of OMRON for any act exceed the individual price of the product on which liability is asserted.

IN NO EVENT SHALL OMRON BE RESPONSIBLE FOR WARRANTY, REPAIR, OR OTHER CLAIMS REGARDING THE PRODUCTS UNLESS OMRON'S ANALYSIS CONFIRMS THAT THE PRODUCTS WERE PROPERLY HANDLED, STORED, INSTALLED, AND MAINTAINED AND NOT SUBJECT TO CONTAMINATION, ABUSE, MISUSE, OR INAPPROPRIATE MODIFICATION OR REPAIR.

### **Application Considerations**

### **SUITABILITY FOR USE**

OMRON shall not be responsible for conformity with any standards, codes, or regulations that apply to the combination of products in the customer's application or use of the products.

At the customer's request, OMRON will provide applicable third party certification documents identifying ratings and limitations of use that apply to the products. This information by itself is not sufficient for a complete determination of the suitability of the products in combination with the end product, machine, system, or other application or use.

The following are some examples of applications for which particular attention must be given. This is not intended to be an exhaustive list of all possible uses of the products, nor is it intended to imply that the uses listed may be suitable for the products:

- Outdoor use, uses involving potential chemical contamination or electrical interference, or conditions or uses not described in this catalog.
- Nuclear energy control systems, combustion systems, railroad systems, aviation systems, medical equipment, amusement machines, vehicles, safety equipment, and installations subject to separate industry or government regulations.
- Systems, machines, and equipment that could present a risk to life or property.

Please know and observe all prohibitions of use applicable to the products.

NEVER USE THE PRODUCTS FOR AN APPLICATION INVOLVING SERIOUS RISK TO LIFE OR PROPERTY WITHOUT ENSURING THAT THE SYSTEM AS A WHOLE HAS BEEN DESIGNED TO ADDRESS THE RISKS, AND THAT THE OMRON PRODUCTS ARE PROPERLY RATED AND INSTALLED FOR THE INTENDED USE WITHIN THE OVERALL EQUIPMENT OR SYSTEM.

# PROGRAMMABLE PRODUCTS

OMRON shall not be responsible for the user's programming of a programmable product, or any consequence thereof.

### **Disclaimers**

### **CHANGE IN SPECIFICATIONS**

Product specifications and accessories may be changed at any time based on improvements and other reasons.

It is our practice to change model numbers when published ratings or features are changed, or when significant construction changes are made. However, some specifications of the products may be changed without any notice. When in doubt, special model numbers may be assigned to fix or establish key specifications for your application on your request. Please consult with your OMRON representative at any time to confirm actual specifications of purchased products.

### **DIMENSIONS AND WEIGHTS**

Dimensions and weights are nominal and are not to be used for manufacturing purposes, even when tolerances are shown.

### PERFORMANCE DATA

Performance data given in this catalog is provided as a guide for the user in determining suitability and does not constitute a warranty. It may represent the result of OMRON's test conditions, and the users must correlate it to actual application requirements. Actual performance is subject to the OMRON Warranty and Limitations of Liability.

### **ERRORS AND OMISSIONS**

The information in this document has been carefully checked and is believed to be accurate; however, no responsibility is assumed for clerical, typographical, or proofreading errors, or omissions.

2013.1

In the interest of product improvement, specifications are subject to change without notice.

